

South Colonie Central School District

Sample Identification #	Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte EPA Method 200.7	Results (ppb)	NYSDOH Action Level	Units	Actions taken for outlets greater than 5ppb
High School									
HS-1	Main Kitchen Faucet under hood	11/14/2023 07:45	11/29/2023 14:30	70278542001	Lead	1.3	5	ug/L	
HS-2	Main Kitchen Double sink	11/14/2023 07:46	11/29/2023 14:37	70278542002	Lead	3.1	5	ug/L	
HS-3	Main Kitchen Serving sink	11/14/2023 07:48	11/29/2023 14:42	70278542003	Lead	2.2	5	ug/L	
HS-4	Main Kitchen Window sink	11/14/2023 07:47	11/29/2023 14:46	70278542004	Lead	25.2	5	ug/L	replace faucet supply tube / retest
HS-4	Main Kitchen Window sink	1/2/2024 09:30	1/5/2024 14:13	70282916005	Lead	2.2	5	ug/L	PASSED
HS-5	West Wing Kitchen sink on left - 3 troughs, 2 faucets	11/14/2023 08:04	11/29/2023 14:48	70278542005	Lead	2.2	5	ug/L	
HS-6	West Wing kitchen sink on right - window wall	11/14/2023 08:04	11/29/2023 14:50	70278542006	Lead	1.9	5	ug/L	
HS-7	Drinking fountain west wing cafeteria	11/14/2023 08:08	11/29/2023 14:51	70278542007	Lead	<1.0	5	ug/L	
HS-8	Drinking fountain near room G78	11/14/2023 08:08	11/29/2023 14:53	70278542008	Lead	<1.0	5	ug/L	
HS-9	Drinking fountain near room G84	11/14/2023 08:08	11/29/2023 14:54	70278542009	Lead	<1.0	5	ug/L	
HS-10	Sink in Trainer's room	11/14/2023 08:20	11/29/2023 14:56	70278542010	Lead	<1.0	5	ug/L	
HS-11	Water spicket in Trainer's Whirlpool room	11/14/2023 08:20	11/29/2023 14:58	70278542011	Lead	<1.0	5	ug/L	
HS-12	Ice machine in Trainer's room	11/14/2023 08:20	11/29/2023 14:59	70278542012	Lead	<1.0	5	ug/L	
HS-13	Drinking fountain Mug hallway near locker rooms	11/14/2023 08:50	11/29/2023 15:01	70278542013	Lead	<1.0	5	ug/L	
HS-14	Drinking fountain Mug Girls locker room	11/14/2023 08:50	11/29/2023 15:06	70278542014	Lead	1.3	5	ug/L	
HS-15	Drinking fountain Mug Lobby	11/14/2023 11:14	11/29/2023 15:07	70278542015	Lead	<1.0	5	ug/L	
HS-16	Drinking fountain outside room 111	11/14/2023 09:48	11/29/2023 15:09	70278542016	Lead	<1.0	5	ug/L	
HS-17	Drinking fountain outside room 115	11/14/2023 09:49	11/29/2023 15:10	70278542017	Lead	<1.0	5	ug/L	
HS-18	Sink in Library work room	11/14/2023 09:51	11/29/2023 15:12	70278542018	Lead	1.2	5	ug/L	
HS-19	Drinking fountain in Library	11/14/2023 09:53	11/29/2023 15:14	70278542019	Lead	<1.0	5	ug/L	
HS-20	Drinking fountain across from room 133 - left	11/14/2023 10:13	11/29/2023 15:15	70278542020	Lead	<1.0	5	ug/L	
HS-21	Drinking fountain across from room 133 - right	11/14/2023 10:13	11/29/2023 15:20	70278542021	Lead	<1.0	5	ug/L	
HS-22	Drinking fountain music wing - across from room 105	11/14/2023 10:11	11/29/2023 15:28	70278542022	Lead	<1.0	5	ug/L	
HS-23	Sink in Faculty room	11/14/2023 09:56	11/29/2023 15:33	70278542023	Lead	<1.0	5	ug/L	
HS-24	Drinking fountain outside main office	11/14/2023 09:26	11/29/2023 15:34	70278542024	Lead	9.7	5	ug/L	removed / replace / retest
HS-24	Drinking fountain outside main office	1/2/2024 09:30	1/5/2024 14:15	70282916006	Lead	<1.0	5	ug/L	PASSED
HS-25	Drinking fountain outside boys locker room	11/14/2023 10:09	11/29/2023 15:36	70278542025	Lead	<1.0	5	ug/L	
HS-26	Drinking fountain west wing near guidance	11/14/2023 10:17	11/29/2023 15:38	70278542026	Lead	<1.0	5	ug/L	
HS-27	Drinking fountain outside main café, towards main entrance	11/14/2023 10:01	11/29/2023 15:39	70278542027	Lead	<1.0	5	ug/L	
HS-28	Drinking fountain inside main Cafe	11/14/2023 10:03	11/29/2023 15:44	70278542028	Lead	<1.0	5	ug/L	
HS-29	Drinking fountain outside kitchen	11/14/2023 10:03	11/29/2023 15:46	70278542029	Lead	<1.0	5	ug/L	
HS-30	Drinking fountain outside room 150	11/14/2023 10:05	11/29/2023 15:47	70278542030	Lead	<1.0	5	ug/L	
HS-31	Drinking fountain across from room 157	11/14/2023 10:05	11/29/2023 15:49	70278542031	Lead	<1.0	5	ug/L	
HS-32	Drinking fountain in the girl's locker room pit	11/14/2023 10:21	11/29/2023 15:51	70278542032	Lead	<1.0	5	ug/L	
HS-33	Drinking fountain outside room 229	11/14/2023 10:46	11/29/2023 15:52	70278542033	Lead	<1.0	5	ug/L	
HS-34	Drinking fountain outside room 225	11/14/2023 10:44	11/29/2023 15:54	70278542034	Lead	<1.0	5	ug/L	
HS-35	Drinking fountain outside room 221	11/14/2023 10:43	11/29/2023 15:55	70278542035	Lead	<1.0	5	ug/L	
HS-36	Drinking fountain outside room 214	11/14/2023 10:39	11/29/2023 15:57	70278542036	Lead	<1.0	5	ug/L	
HS-37	Drinking fountain west wing near room 242	11/14/2023 10:50	11/29/2023 15:59	70278542037	Lead	<1.0	5	ug/L	
HS-38	Drinking fountain outside room 211	11/14/2023 10:30	11/29/2023 16:03	70278542038	Lead	<1.0	5	ug/L	

HS-39	Drinking fountain outside room 207	11/14/2023 10:31	11/29/2023 16:05	70278542039	Lead	<1.0	5	ug/L	
HS-40	Drinking fountain outside room 202	11/14/2023 10:32	11/29/2023 16:06	70278542040	Lead	<1.0	5	ug/L	
HS-41	Cintas Waterbreak in nurse's office	11/14/2023 10:24	11/29/2023 16:11	70278542041	Lead	<1.0	5	ug/L	
Lisha Kill MS									
LK-1	Sink in kitchen along cafeteria wall - left	11/14/2023 12:54	11/29/2023 16:16	70278542042	Lead	<1.0	5	ug/L	
LK-2	Sink in kitchen along cafeteria wall - middle	11/14/2023 12:54	11/29/2023 16:24	70278542043	Lead	<1.0	5	ug/L	
LK-3	Sink in kitchen along cafeteria wall - right	11/14/2023 12:54	11/29/2023 16:26	70278542044	Lead	2.4	5	ug/L	
LK-4	Drinking fountain in back of Cafeteria	11/14/2023 12:47	11/29/2023 16:58	70278542045	Lead	<1.0	5	ug/L	
LK-5	Drinking fountain in hallway outside Kitchen	11/14/2023 12:52	11/29/2023 16:29	70278542046	Lead	<1.0	5	ug/L	
LK-6	Sink in room 139	11/14/2023 13:24	11/29/2023 16:31	70278542047	Lead	<1.0	5	ug/L	
LK-7	Drinking fountain outside faculty bathrooms	11/14/2023 12:58	11/29/2023 16:32	70278542048	Lead	<1.0	5	ug/L	
LK-8	Sink on left as entering the room in 125	11/14/2023 13:09	11/29/2023 16:34	70278542049	Lead	15.3	5	ug/L	replace faucet supply tube / retest
LK-8	Sink on left as entering the room in 125	12/13/2023 12:40	12/18/2023 15:49	70281102005	Lead	<1.0	5	ug/L	PASSED
LK-9	Left sink on window wall in room 125	11/14/2023 13:10	11/29/2023 16:35	70278542050	Lead	12.7	5	ug/L	replace faucet supply tube / retest
LK-9	Left sink on window wall in room 125	12/13/2023 12:40	12/18/2023 15:53	70281102006	Lead	1.4	5	ug/L	PASSED
LK-10	Right sink on classroom wall in room 125	11/14/2023 13:09	11/29/2023 16:37	70278542051	Lead	10.5	5	ug/L	replace faucet supply tube / retest
LK-10	Right sink on classroom wall in room 125	12/13/2023 12:40	12/18/2023 15:55	70281102007	Lead	4.2	5	ug/L	PASSED
LK-11	Sink to the right as entering room 125	11/14/2023 13:10	11/29/2023 16:42	70278542052	Lead	13.0	5	ug/L	replace faucet supply tube / retest
LK-11	Sink to the right as entering room 125	12/13/2023 12:40	12/18/2023 15:56	70281102008	Lead	<1.0	5	ug/L	PASSED
LK-12	Drinking fountain outside room 121	11/14/2023 13:07	11/29/2023 16:44	70278542053	Lead	<1.0	5	ug/L	
LK-13	Drinking fountain outside room 101	11/14/2023 13:11	11/29/2023 16:46	70278542054	Lead	<1.0	5	ug/L	
LK-14	Drinking fountain outside room 109	11/14/2023 13:13	11/29/2023 16:48	70278542055	Lead	15.4	5	ug/L	removed / out of commission
LK-15	Drinking fountain outside room 211	11/14/2023 13:19	11/29/2023 16:50	70278542056	Lead	20.2	5	ug/L	removed / out of commission
LK-16	Drinking fountain outside room 201	11/14/2023 13:18	11/29/2023 16:51	70278542057	Lead	<1.0	5	ug/L	
LK-17	Drinking fountain outside room 151	11/14/2023 13:05	11/29/2023 16:53	70278542058	Lead	<1.0	5	ug/L	
LK-18	Drinking fountain in exercise room	11/14/2023 12:51	11/29/2023 16:55	70278542059	Lead	5.7	5	ug/L	removed / out of commission
LK-19	Drinking fountain hallway between gyms - closet to Old Gym	11/14/2023 13:02	11/29/2023 16:56	70278542060	Lead	<1.0	5	ug/L	
LK-20	Drinking fountain hallway between gyms - closet to New Gym	11/14/2023 13:03	11/29/2023 17:06	70278542061	Lead	<1.0	5	ug/L	
LK-21	Cintas Waterbreak outside PPS offices in basement	11/14/2023 12:56	11/29/2023 17:11	70278542062	Lead	<1.0	5	ug/L	
LK-22	Cintas Waterbreak in nurse's office	11/14/2023 12:59	11/29/2023 17:51	70278542063	Lead	<1.0	5	ug/L	
Sand Creek MS									
SC-1	Kitchen, double sink	11/14/2023 11:14	11/29/2023 17:17	70278542064	Lead	5.2	5	ug/L	replace faucet supply tube / retest
SC-1	Kitchen, double sink	12/13/2023 10:30	12/18/2023 15:34	70281102001	Lead	1.6	5	ug/L	PASSED
SC-2	Kitchen, wall under window	11/14/2023 11:15	11/29/2023 17:22	70278542065	Lead	46.5	5	ug/L	replace faucet supply tube / retest
SC-2	Kitchen, wall under window	12/13/2023 10:30	12/18/2023 15:35	70281102002	Lead	1.7	5	ug/L	PASSED
SC-3	Kitchen, middle counter near register	11/14/2023 11:16	11/29/2023 17:23	70278542066	Lead	7.3	5	ug/L	replace faucet supply tube / retest
SC-3	Kitchen, middle counter near register	12/13/2023 10:31	12/18/2023 15:37	70281102003	Lead	2.6	5	ug/L	PASSED
SC-22	Kitchen, island near freezer	12/13/2023 10:31	12/18/2023 15:41	70281102004	Lead	3.5	5	ug/L	PASSED
SC-4	Drinking fountain main entrance	11/14/2023 11:17	11/29/2023 17:25	70278542067	Lead	<1.0	5	ug/L	
SC-5	Drinking fountain outside room 114	11/14/2023 11:19	11/29/2023 17:27	70278542068	Lead	<1.0	5	ug/L	
SC-6	Drinking fountain by weight room	11/14/2023 11:25	11/29/2023 17:28	70278542069	Lead	<1.0	5	ug/L	
SC-7	Drinking fountain in gym lobby	11/14/2023 11:22	11/29/2023 17:30	70278542070	Lead	<1.0	5	ug/L	
SC-8	Drinking fountain outside room 175	11/14/2023 11:20	11/29/2023 17:31	70278542071	Lead	<1.0	5	ug/L	
SC-9	Drinking fountain near Room 153	11/14/2023 11:27	11/29/2023 17:33	70278542072	Lead	<1.0	5	ug/L	
SC-10	Sink in room 135	11/14/2023 11:32	11/29/2023 17:35	70278542073	Lead	1.9	5	ug/L	

SC-11	Sink in room 141 East wall as entering	11/14/2023 11:30	11/29/2023 17:36	70278542074	Lead	8.7	5	ug/L	replace faucet supply tube / retest
SC-11	Sink in room 141 East wall as entering	1/2/2024 09:00	1/5/2024 13:53	70282916001	Lead	2.7	5	ug/L	PASSED
SC-12	Sink in room 141 East wall near windows	11/14/2023 11:32	11/29/2023 17:41	70278542075	Lead	2.9	5	ug/L	replace faucet supply tube / retest
SC-12	Sink in room 141 East wall near windows	1/2/2024 09:00	1/5/2024 13:54	70282916002	Lead	21.0	5	ug/L	replace valve / retest
SC-12	Sink in room 141 East wall near windows	2/1/2024 11:30	2/5/2024 12:47	70286052003	Lead	<1.0	5	ug/L	PASSED
SC-13	Sink in room 141 as entering to the right, hall wall	11/14/2023 11:31	11/29/2023 17:43	70278542076	Lead	5.8	5	ug/L	replace faucet supply tube / retest
SC-13	Sink in room 141 as entering to the right, hall wall	1/2/2024 09:00	1/5/2024 14:02	70282916003	Lead	1.9	5	ug/L	PASSED
SC-14	Sink in room 141 to the right as entering, farthest sink	11/14/2023 11:32	11/29/2023 17:44	70278542077	Lead	13.6	5	ug/L	replace faucet supply tube / retest
SC-14	Sink in room 141 to the right as entering, farthest sink	1/2/2024 09:00	1/5/2024 15:31	70282916004	Lead	3.4	5	ug/L	PASSED
SC-15	Drinking fountain near Room 203	11/14/2023 11:42	11/29/2023 17:46	70278542078	Lead	<1.0	5	ug/L	
SC-16	Drinking fountain near Room 214	11/14/2023 11:44	11/29/2023 17:47	70278542079	Lead	<1.0	5	ug/L	
SC-17	Sink in room 227	11/14/2023 11:54	11/29/2023 17:49	70278542080	Lead	1.4	5	ug/L	
SC-18	Drinking fountain near Room 237	11/14/2023 11:52	11/29/2023 17:55	70278542081	Lead	18.9	5	ug/L	removed / out of commission
SC-19	Drinking fountain near Room 253	11/14/2023 11:50	11/29/2023 18:03	70278542082	Lead	<1.0	5	ug/L	
SC-20	Drinking fountain in Cafeteria	11/14/2023 11:34	11/29/2023 18:08	70278542083	Lead	<1.0	5	ug/L	
SC-21	Sink in copy room off of main office	11/14/2023 11:37	11/29/2023 18:10	70278542084	Lead	4.1	5	ug/L	
Forest Park Elementary									
FP-1	Kitchen double pot sink	11/14/2023 14:51	11/29/2023 18:11	70278542085	Lead	15.7	5	ug/L	replace faucet supply tube / retest
FP-1	Kitchen double pot sink	1/2/2024 10:05	1/5/2024 14:20	70282916007	Lead	9.0	5	ug/L	replace valves at boiler / retest
FP-1	Kitchen double pot sink	1/22/2024 10:45	1/25/2024 11:01	70285038001	Lead	222	5	ug/L	flush system / replace screen / retest
FP-1	Kitchen double pot sink	2/1/2024 11:25	2/5/2024 12:41	70286052001	Lead	<1.0	5	ug/L	PASSED
FP-2	Kitchen gooseneck sink	11/14/2023 14:52	11/29/2023 18:13	70278542086	Lead	43.6	5	ug/L	replace faucet supply tube / retest
FP-2	Kitchen gooseneck sink	1/2/2024 10:05	1/5/2024 14:21	70282916008	Lead	9.7	5	ug/L	replace valves at boiler / retest
FP-2	Kitchen gooseneck sink	1/22/2024 10:45	1/25/2024 11:03	70285038002	Lead	5.3	5	ug/L	flush system / replace faucet / retest
FP-2	Kitchen gooseneck sink	2/1/2024 11:25	2/5/2024 12:46	70286052002	Lead	<1.0	5	ug/L	PASSED
FP-3	Drinking fountain outside gym	11/14/2023 15:00	11/29/2023 18:15	70278542087	Lead	<1.0	5	ug/L	
FP-4	Drinking fountain outside kitchen	11/14/2023 14:50	11/29/2023 18:19	70278542088	Lead	<1.0	5	ug/L	
FP-5	Sink in Staff Room	11/14/2023 14:48	11/29/2023 18:21	70278542089	Lead	2.3	5	ug/L	
FP-6	Drinking fountain outside room 24	11/14/2023 14:48	11/29/2023 18:22	70278542090	Lead	<1.0	5	ug/L	
FP-7	Drinking fountain outside room 9	11/14/2023 14:49	11/29/2023 18:24	70278542091	Lead	<1.0	5	ug/L	
FP-8	Drinking fountain outside library (right)	11/14/2023 14:45	11/29/2023 18:26	70278542092	Lead	<1.0	5	ug/L	
FP-9	Drinking fountain outside main office	11/14/2023 14:41	11/29/2023 18:27	70278542093	Lead	<1.0	5	ug/L	
FP-10	Cintas Waterbreak in nurse's office	11/14/2023 14:42	11/29/2023 18:29	70278542094	Lead	<1.0	5	ug/L	
Roesseville Elementary									
RV-1	Kitchen sink - left	11/15/2023 08:04	11/29/2023 18:30	70278542095	Lead	<1.0	5	ug/L	
RV-2	Kitchen sink - right	11/15/2023 08:05	11/29/2023 18:32	70278542096	Lead	1.6	5	ug/L	
RV-3	Drinking fountain near cafeteria	11/15/2023 07:51	11/29/2023 18:33	70278542097	Lead	<1.0	5	ug/L	
RV-4	Drinking fountain in gym	11/15/2023 07:52	11/29/2023 18:38	70278542098	Lead	<1.0	5	ug/L	
RV-5	Drinking fountain near room 105	11/15/2023 08:00	11/29/2023 18:40	70278542099	Lead	<1.0	5	ug/L	
RV-6	Drinking fountain upstairs (right)	11/15/2023 08:01	11/29/2023 18:41	70278542100	Lead	<1.0	5	ug/L	
RV-7	Drinking fountain upstairs (left)	11/15/2023 08:02	11/29/2023 18:46	70278542101	Lead	<1.0	5	ug/L	
RV-8	Sink in faculty room	11/15/2023 07:54	11/29/2023 18:51	70278542102	Lead	<1.0	5	ug/L	
RV-9	Cintas Waterbreak in nurse's office	11/12/2023 08:01	12/1/2023 15:26	70278999002	Lead	<1.0	5	ug/L	
Saddlewood Elementary									
SW-1	Sink in Kitchen	11/15/2023 09:32	11/30/2023 13:03	70278542104	Lead	2.0	5	ug/L	

SW-2	Drinking fountain outside Gym	11/15/2023 09:34	11/29/2023 19:00	70278542105	Lead	<1.0	5	ug/L	
SW-3	Drinking fountain near boys/girls gang toilets	11/15/2023 09:41	11/29/2023 19:02	70278542106	Lead	<1.0	5	ug/L	
SW-4	Drinking fountain outside faculty room	11/15/2023 09:37	11/29/2023 19:04	70278542107	Lead	<1.0	5	ug/L	
SW-5	Drinking fountain near room 4	11/15/2023 09:37	11/29/2023 19:05	70278542108	Lead	<1.0	5	ug/L	
SW-6	Cintas Waterbreak in nurse's office	11/15/2023 09:35	11/29/2023 19:07	70278542109	Lead	<1.0	5	ug/L	
SW-7	Sink in Faculty Room	11/15/2023 09:38	11/30/2023 13:04	70278542110	Lead	<1.0	5	ug/L	
Shaker Road Elementary									
SR-1	Sink in Kitchen	11/14/2023 14:08	11/29/2023 19:10	70278542111	Lead	1.8	5	ug/L	
SR-2	Drinking fountain outside Gym	11/14/2023 14:09	11/29/2023 19:12	70278542112	Lead	<1.0	5	ug/L	
SR-3	Drinking fountain near boys/girls gang toilets	11/14/2023 14:16	11/29/2023 19:16	70278542113	Lead	<1.0	5	ug/L	
SR-4	Drinking fountain outside faculty room	11/14/2023 14:13	11/29/2023 19:18	70278542114	Lead	<1.0	5	ug/L	
SR-5	Drinking fountain near room 25	11/14/2023 14:15	11/29/2023 19:19	70278542115	Lead	<1.0	5	ug/L	
SR-6	Cintas Waterbreak in nurse's office	11/14/2023 14:11	11/29/2023 19:21	70278542116	Lead	<1.0	5	ug/L	
SR-7	Sink in faculty room	11/14/2023 14:15	11/29/2023 19:23	70278542117	Lead	3.8	5	ug/L	
Veeder Elementary									
VR-1	Kitchen sink in island	11/15/2023 08:32	11/29/2023 19:24	70278542118	Lead	1.3	5	ug/L	
VR-2	Sink in staff room	11/15/2023 08:34	11/29/2023 19:26	70278542119	Lead	<1.0	5	ug/L	
VR-3	Drinking fountain outside kitchen	11/15/2023 08:35	11/29/2023 19:27	70278542120	Lead	<1.0	5	ug/L	
VR-4	Drinking fountain across from B1	11/15/2023 08:44	11/29/2023 19:29	70278542121	Lead	<1.0	5	ug/L	
VR-5	Cintas Waterbreak in nurse's office	11/15/2023 08:45	11/29/2023 19:37	70278542122	Lead	<1.0	5	ug/L	
VR-6	Drinking fountain A wing outside Boys Bathroom	11/15/2023 08:42	11/29/2023 19:42	70278542123	Lead	<1.0	5	ug/L	
VR-7	Drinking fountain across from C7	11/15/2023 08:40	11/29/2023 19:43	70278542124	Lead	<1.0	5	ug/L	
VR-8	Drinking fountain outside the gym	11/15/2023 08:36	11/29/2023 19:45	70278542125	Lead	<1.0	5	ug/L	
VR-9	Bubbler in C1	11/15/2023 08:37	11/29/2023 19:47	70278542126	Lead	9.4	5	ug/L	removed / out of commission
VR-10	Bubbler in C2	11/12/2023 08:22	12/1/2023 15:24	70278999001	Lead	1.2	5	ug/L	removed / out of commission
VR-11	Bubbler in room C3	11/21/2023 07:55	11/29/2023 19:48	70278542128	Lead	<1.0	5	ug/L	removed / out of commission

NYSDOH Action Level for Lead In Schools of 5 ppb